FPSS Fire Protection Survey Services

## CERTIFICATE OF WATER TANKER SHUTTLE ACCREDITATION

Presented to

## Stirling-Rawdon Fire Department

F.S. Stirling F.S. Spring Brook

**Date Test Passed: September 3rd, 2020** 

Flow Achieved: \_\_\_430\_\_\_ I.G.P.M Liters Per Min: \_\_1960\_\_ Two (2) Hour Test Time

Signed: *\_Melissa Rose\_* Melissa Rose – Principal

This Certificate is valid for 5 years and expires September 4th, 2025